

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023-2025
Data Response

PG&E Data Request No.:	MGRA_009-Q008		
PG&E File Name:	WMP-Discovery2023-2025_DR_MGRA_009-Q008		
Request Date:	April 8, 2024	Requester DR No.:	MGRA Data Request No. 2
Date Sent:	April 11, 2024	Requesting Party:	Mussey Grade Road Alliance
PG&E Witness:		Requester:	Joseph Mitchell

PS-07: Reduce PSPS Impacts to Customers (Section 9.1.5)

QUESTION 008

If not, is EPSS enabled based on weather conditions and if so how?

ANSWER 008

Yes, EPSS is enabled and disabled based on forecasted weather conditions. EPSS settings are enabled or disabled based on criteria approved by our Wildfire Risk Governance Steering Committee. This criteria is based on 2km-by-2km model outputs from our Fire Potential Index (FPI) model. PG&E's FPI model is trained to identify localized wildfire risk based on a variety of key risk indicators derived from fire science as well as lessons learned from previous catastrophic wildfires.