

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans Discovery 2023-2025**  
**Data Response**

PG&E Data Request No.:	MGRA_009-Q007		
PG&E File Name:	WMP-Discovery2023-2025_DR_MGRA_009-Q007		
Request Date:	April 8, 2024	Requester DR No.:	MGRA Data Request No. 2
Date Sent:	April 11, 2024	Requesting Party:	Mussey Grade Road Alliance
PG&E Witness:		Requester:	Joseph Mitchell

**PS-07: Reduce PSPS Impacts to Customers (Section 9.1.5)**

**QUESTION 007**

Does MSO also allow for EPSS to be enabled as a function of weather conditions?

**ANSWER 007**

Motor Switch Operator (MSO) devices are not capable of fault protection and therefore are not part of EPSS. As part of the MSO initiative in the WMP, these units are being replaced with either a line recloser, an automated switch, or a manual switch. If the line recloser option is selected, those replaced devices will have EPSS capability and be enabled during EPSS weather conditions.