

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response

PG&E Data Request No.:	TURN_025-Q04		
PG&E File Name:	WildfireMitigationPlans_DR_TURN_025-Q04		
Request Date:	March 11, 2021	Requester DR No.:	WMP 2021 DR TURN-PGE-011
Date Sent:	March 15, 2021	Requesting Party:	The Utility Reform Network
PG&E Witness:		Requester:	Marcel Hawiger

QUESTION 04

Please provide the name of all manufacturers from whom PG&E obtained covered conductor in 2019 and 2020, and identify the types of covered conductor that were procured from each manufacturer.

ANSWER 04

For the purposes of this response, PG&E is interpreting “covered conductor” in the question as primary covered tree wire. The table below lists the parts and manufacturers used to obtain the covered conductor in 2019 and 2020.

Part	Manufacturer		
	Southwire	Taihan	Marmon Utilities (Hendrix)
#2-7 HD Cu XLPE Tree Wire	X		
1/0-6/1 ACSR XLPE Tree Wire	X	X	X (2019 only)
397.5-19 AAC XLPE Tree Wire	X	X	X
715.5-37 AAC XLPE Tree Wire	X	X	X (2019 only)