

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2022  
Data Response**

PG&E Data Request No.:	OEIS_002-Q10		
PG&E File Name:	WMP-Discovery2022_DR_OEIS_002-Q10		
Request Date:	February 22, 2022	Requester DR No.:	Data Request OEIS-PG&E-22-002
Date Sent:	March 4, 2022	Requesting Party:	Office of Energy Infrastructure Safety
PG&E Witness:		Requester:	Kevin Miller

**D. Asset Management and Inspections**

**QUESTION 10**

Regarding PG&E's response to Maturity Survey question D.I.b (*Does all equipment in HFTD areas have the ability to detect and respond to malfunctions?*):

- a. Why does PG&E only update asset condition annually?
- b. Provide all existing bottlenecks that prevent PG&E from updating its asset conditions more frequently, including any plans to alleviate such bottlenecks.'

**ANSWER 10**

- a. Asset conditions update daily as inspections, maintenance and other project and programs are completed. However, for the purpose of asset management planning, PG&E's system is relatively stable and conditions do not change dynamically enough to necessitate more frequent updates. Many of the use cases for the condition data are developed into annual work plans.
- b. PG&E has determined to update asset planning health models annually for the purpose of work planning. Version control and management of change of the condition data and subsequent health models are some key reasons why models are not updated more frequently.