PACIFIC GAS AND ELECTRIC COMPANY Wildfire Mitigation Plans Discovery 2023 Data Response

PG&E Data Request No.:	CalAdvocates_008-Q019		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_008-Q019		
Request Date:	March 30, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-08
Date Sent:	April 5, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

SUBJECT: 2023-2025 WMP SUBMISSION

QUESTION 019

Table 8-19, Priority 1/Priority 2 and Second Patrol Trees Categorized By Age, shows 296 priority 1 or 2 trees that were inspected more than 180 days prior to February 28, 2023.22

Please provide a table with the following additional information for these 296 trees:

- a) The exact number of days since the last inspection, as of February 28, 2023
- b) The current priority level of the tree
- c) The type of the most recent inspection
- d) The HFTD tier where the tree is located
- e) PG&E's expected remediation date for the tree.

ANSWER 019

The data for the 296 P1/P2/Second Patrol trees can be found on "WMP-Discovery2023_DR_CalAdvocates_008-Q019Atch01.xlsx"

For the 3 Priority 1/Priority 2 Trees out of the set of 296, please refer to tab 'P2 Data'.

- a) Please see 'Age' in 'Column I' on tab 'P2 Data' for the age in days since the last inspection as of February 28, 2022.
- b) Please see 'Priority' in 'Column E' on tab 'P2 Data' for the priority level.
 - If vegetation is determined to be an immediate risk to PG&E facilities, described as a Priority 1 Condition, the condition will be mitigated within 24 hours of identification as long as conditions are safe for the tree crew to proceed with work.
 - Vegetation identified as pending Priority 2 work within the RFW area will be reviewed and mitigated as outlined in the VM Priority Tag Procedure (TD-7102P-17).

²² PG&E's WMP, p. 557.

- c) Please see 'dtInspDate' in 'Column D' on tab 'P2 Data' for the Inspection date.
- d) Please see 'iHFTDTier' 'Column H' on tab 'P2 Data' for the HFTD Tier.
- e) We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time.

For the 293 trees out of the set of 296, please refer to tab 'TM Data'. Please note, the quantity of trees that correspond to the 'TreeRecsID' can be located on 'Column L' of the 'TM Data' tab in attachment.

- a) Please see 'Age' in 'Column J' on tab 'TM Data' for the age in days since the last inspection as of February 28, 2022.
- b) Please see 'Priority' in 'Column F' on tab 'TM Data' for the priority level.
 - 'Routine' classification is normal compliance work prioritized to be complete during the normal work cycle.
 - 'Expanded' classification is work that needs to be completed as part of reliability.
 - 'Accelerated' classification are trees that are out of compliance and need to be worked before the next work cycle occurs.
- c) Please see 'dtInspDate' in 'Column D' on tab 'TM Data' for the last inspection date as of February 28, 2022.
- d) Please see 'iHFTDTier' in 'Column K' on tab 'TM Data' for the HFTD tier.
- e) We do not have a source for tracking planned worked date for individual trees and are unable to provide the data at this time.