

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2023  
Data Response**

PG&E Data Request No.:	CalAdvocates_014-Q011		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_014-Q011		
Request Date:	April 11, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-14
Date Sent:	April 17, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission.

**QUESTION 011**

P. 400 of PG&E's WMP states,

“PG&E designated plat maps as extreme, severe, high, medium, or low based on the average wildfire consequence of the structures within that plat map.”

- a) Is the designation described above based on the wildfire consequence scores from the WDRM v2 or the WDRM v3?
- b) How frequently does PG&E plan to re-evaluate the plat map designations described above?
- c) When PG&E re-evaluates the plat map designations, what steps will it take regarding a plat map that has increased in severity, such as from high to severe or severe to extreme?

**ANSWER 011**

- a) The quote referenced above is based on the wildfire consequence scores from the WDRM v3.
- b) We plan to review wildfire risk model results annually and evaluate how to update the inspection plan accordingly.
- c) After we review risk model results each year, we will evaluate whether the plan needs to be adjusted. Updates to the plan may include reassigning a plat map to a different consequence tier or adding individual structures to the inspection plan to account for increased risk or consequence.