

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2023  
Data Response**

PG&E Data Request No.:	GPI_002-Q002		
PG&E File Name:	WMP-Discovery2023_DR_GPI_002-Q002		
Request Date:	May 11, 2023	Requester DR No.:	GPI-PGE-2023WMP-02
Date Sent:	May 16, 2023	Requesting Party:	Green Power Institute
DRU Index #:		Requester:	Zoe Harrold, Ph.D.

The following questions relate to your 2023-2025 WMP submission.

**QUESTION 002**

Please provide the number of distribution line miles PG&E will perform trimming on to achieve enhanced clearances (> 12').

**ANSWER 002**

There are approximately 40,000 HFTD and HFRA miles in PG&E service territory.

PG&E performs inspection on all line miles within HFRA and HFTD areas. While PG&E does not have a program dedicated to enhanced clearances, we are following the prescription in General Order 95, Rule 35 and our Distribution Standards which recommends a minimum 12-feet of clearance at time of trim in High Fire-Threat District (HFTD). PG&E also extends this minimum clearance recommendation to tree work within HFRA.