

**PACIFIC GAS AND ELECTRIC COMPANY  
Wildfire Mitigation Plans Discovery 2023  
Data Response**

PG&E Data Request No.:	CalAdvocates_019-Q006		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_019-Q006		
Request Date:	April 25, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-19
Date Sent:	April 28, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission and your responses to data request CalAdvocates-PGE-2023WMP-15.

**QUESTION 006**

- a) Please describe the vegetation management activities that PG&E currently undertakes on rights-of-way with underground lines in the HFTD.
- b) Please describe any changes PG&E plans to make during the 2023-2025 WMP period regarding the vegetation management activities that PG&E plans to undertake on rights-of way with underground lines in the HFTD.
- c) Please provide any protocols, procedures, or manuals that describe PG&E's approach to vegetation management where PG&E has underground lines in the HFTD.

**ANSWER 006**

- a) Where there are no overhead electric facilities, we do not conduct routine vegetation management activities. As part of GO 165, the PG&E System Inspection program can identify vegetation work as part of clearing and maintenance for padmount transformers and other typical undergrounding equipment.
- b) Not applicable.
- c) Not applicable.

.