

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response**

PG&E Data Request No.:	CalAdvocates_042-Q06		
PG&E File Name:	WildfireMitigationPlans_DR_CalAdvocates_042-Q06		
Request Date:	February 21, 2021	Requester DR No.:	CalAdvocates-PGE-2021WMP-08
Date Sent:	February 25, 2021	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Henry Burton

SUBJECT: ENHANCED VEGETATION MANAGEMENT (EVM)

The following questions related to PG&E's 2021 Wildfire Mitigation Plan (WMP) Update.

QUESTION 06

- a) State the average cost to perform an EVM work verification inspection in the HFTD in 2020.
- b) On average, how many circuit miles were inspected in a single EVM work verification inspection in the HFTD in 2020?

ANSWER 06

- a. The average cost to perform an EVM work verification inspection was approximately \$152 for 2020.
- b. On average 0.06 miles were inspected in a single EVM work verification inspection in 2020.