

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_008-Q018		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_008-Q018		
Request Date:	March 30, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-08
Date Sent:	April 5, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

SUBJECT: 2023-2025 WMP SUBMISSION

QUESTION 018

PG&E's WMP states, in Table 8-18-3, VM Field QC Metrics Report, that pass rates are "not a WMP target" for 2023-2025.²¹

Please explain why PG&E has not set target pass rates for VM Field QC for 2023-2025.

ANSWER 018

The Quality Management team has aligned on setting target pass rates at 88% for Field Quality Control Active Observation Programs for the following core vegetation management programs: Routine Distribution, Second Patrol Distribution, Vegetation Control, and Routine Transmission.

²¹ PG&E's WMP, p. 555.