

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_011-Q010		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_011-Q010		
Request Date:	April 5, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-11
Date Sent:	April 10, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Pui-Wa LI

The following questions relate to your 2023-2025 WMP submission and also the following documents:

- PG&E's 2022 WMP, Section 7.1.E, Attachment 1 (Attch_Q3.pdf),
- PG&E's presentation during the 2021 EPIC Symposium (Attch_Q6_EPIC_Presentation.pdf),
- PG&E's Electric Preliminary Statement Part FY (Tariff Sheet No. 52259-E), and
- PG&E's Test Year 2023 GRC, Application 21-06-021, Exhibit PG&E-04 and Exhibit PG&E-17.

TOPIC: RAPID EARTH FAULT CURRENT LIMITER (REFCL)

QUESTION 010

Has PG&E done any benchmarking study on REFCL with Southern California Edison (SCE)?

ANSWER 010

Yes, PG&E REFCL project engineers regularly engage with Southern California Edison to benchmark our findings and share results and learnings. Of note, SCE has fewer circuit miles of existing underground cable at their REFCL demonstration site.