

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_014-Q004		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_014-Q004		
Request Date:	April 11, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-14
Date Sent:	April 17, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission.

QUESTION 004

P. 359 of PG&E's WMP states, "Breakaway disconnect does not impact PSPS Risk."
Please state the basis for the above quote.

ANSWER 004

Breakaway disconnects are used to prevent energized wire down to minimize ignition risk. At this point in time, of the presence of breakaway disconnects is not included in PSPS scoping decisions, therefore, breakaway disconnects do not impact the PSPS risk.