

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans Discovery 2023**  
**Data Response**

|                        |  |                   |                       |
|------------------------|--|-------------------|-----------------------|
| PG&E Data Request No.: | GPI_002-Q002                           |                   |                       |
| PG&E File Name:        | WMP-Discovery2023_DR_GPI_002-Q002Rev01 |                   |                       |
| Request Date:          | May 11, 2023                           | Requester DR No.: | GPI-PGE-2023WMP-02    |
| Date Sent:             | May 16, 2023<br>Rev01: April 3, 2024   | Requesting Party: | Green Power Institute |
| DRU Index #:           |  | Requester:        | Zoe Harrold, Ph.D.    |

The following questions relate to your 2023-2025 WMP submission.

**QUESTION 002**

Please provide the number of distribution line miles PG&E will perform trimming on to achieve enhanced clearances (> 12').

**ANSWER 002 REVISED 01**

PG&E does not have any procedural guidance requiring trimming beyond 12 feet on any program, including the Enhanced Vegetation Management (EVM) Program, which concluded at the end of 2022. PG&E follows the recommendation in General Order 95, Rule 35, Appendix E, and PG&E Distribution Standards which recommend a minimum 12-foot radial clearance at time of trim in High Fire-Threat Districts (HFTD). PG&E also extends this minimum clearance recommendation to tree work within HFRA when possible. For these reasons, PG&E is unable to quantify how many distribution line miles are trimmed beyond 12 feet.

There are approximately 26,000 HFTD/HFRA circuit miles within PG&E service territory.