

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	MGRA_002-Q003		
PG&E File Name:	WMP-Discovery2023_DR_MGRA_002-Q003		
Request Date:	April 20, 2023	Requester DR No.:	MGRA-PGE-WMP23_No.2
Date Sent:	April 25, 2023	Requesting Party:	Mussey Grade Road Alliance
DRU Index #:		Requester:	Joseph Mitchell

REFCL

With regard to PG&E's response to CalPA_Set WMP-11_Q14: PG&E states that one of the significant changes to the grid required for REFCL is "The replacement of old, direct bury underground cable":

QUESTION 003

Does PG&E's future undergrounding plans include "direct bury" and if so would that make these segments incompatible with REFCL?

ANSWER 003

No, PG&E's undergrounding plans include cable in conduit with standard voltage ratings exceeding REFCL operating voltage.