

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	SPD_004-Q002		
PG&E File Name:	WMP-Discovery2023_DR_SPD_004-Q002		
Request Date:	May 5, 2023	Requester DR No.:	SPD_PG&E_2023_004
Date Sent:	May 17, 2023	Requesting Party:	Safety Policy Division
DRU Index #:		Requester:	Henry Sweat

SUBJECT: DATA SPD_PG&E_2023_004 DUE FRIDAY 5/12

QUESTION 002

In addition to the data requested above, please add the following data columns for each ignition:

- a. "HFTD" – Classify each ignition as whether it was located in a "Zone 1," "Tier 2" or "Tier 3", "HFRA" or "Non-HFTD"
- b. "Fire Potential Index" – Provide the Fire Potential Index for the location on the day of each ignition.

ANSWER 002

Please find the requested information attached as "*WMP-Discovery2023_DR_SPD_004-Q001Atch01.xlsx*."

- a. The requested information is identified in column H.
- b. The requested information is identified in column E.

Please Note:

For column E (FPI), the Fire Potential Index (FPI) rating is only assigned to locations in a Fire Index Area (FIA), which are polygons that typically (but not always) align with HFTDs. The ignitions that have blanks in column E did not occur on a circuit segment located in a FIA polygon and therefore do not have associated Fire Potential Index ratings.

For column L (Acreage), this field is used to capture acreage for wildfires (i.e. fires greater than 10 acres). It will not typically be populated if the fire is less than 10 acres unless the acreage is listed in a report from a fire suppressing agency.