

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_014-Q024		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_014-Q024		
Request Date:	April 11, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-14
Date Sent:	April 17, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission.

QUESTION 024

- a) In 2022, how many ignitions did PG&E experience related to overhead secondary distribution lines?
- b) In 2022, how many ignitions did PG&E experience related to overhead service lines?

ANSWER 024

- a) In 2022, PG&E observed 44 CPUC reportable ignitions associated with overhead secondary facilities.
- b) In 2022, PG&E observed 54 CPUC reportable ignitions associated with overhead distribution service facilities.