



Electric Sample Form No. 79-1208
Standalone Power System Supplemental Provisions

Sheet 1

**Please Refer to Attached
Sample Form**

(Continued)

Advice 6623-E
Decision

Issued by
Meredith Allen
Vice President, Regulatory Affairs

Submitted June 22, 2022
Effective January 12, 2023
Resolution

STANDALONE POWER SYSTEM SUPPLEMENTAL PROVISIONS

1. Applicant will receive electric service at Applicant's premises in a Remote Grid service arrangement from a distribution system with power supplied by a Standalone Power System. These services shall be installed in accordance with these Supplemental Provisions, the provisions of PG&E Electric Rules 2, 15 and 16, the Distribution and Service Extension Agreement- Provisions, General Terms and Conditions, project specific terms and conditions, design and specifications. To the extent the requirements of these Supplemental Provisions conflict with such Rules and agreements, the requirements of these Supplemental Provisions shall govern.
2. **Standalone Power System Installations on Applicant's Premises.**
 - A. Applicant's Responsibility. In accordance with PG&E's design, specifications, and requirements for the installation of Service Extensions generated by a Standalone Power System, subject to PG&E's inspection and approval, Applicant is responsible for:
 - 1) Space for Standalone Power System Equipment. Applicant shall provide space, if needed, on Applicant's Premises at a location approved by PG&E for a standard Standalone Power System installation. Easements may be required by PG&E to install the Standalone Power System on Applicant's Premises to serve only the Applicant. If the Standalone Power System Equipment will be or is designed to serve other third party properties, then PG&E may at its option install such equipment after appropriate rights of way or easements are obtained, satisfactory to PG&E. Detailed information on PG&E's requirements for the Standalone Power System will be furnished by PG&E.
 - B. PG&E's Responsibility. PG&E will furnish, install, own, and maintain the following Standalone Power System equipment as applicable after Applicant meets all requirements to receive service:
 - 1) Standalone Power System: The Standalone Power System equipment will include photovoltaic panels, battery storage, backup fuel powered generator, and other associated equipment and facilities, where required. The construction of the Standalone Power System area, including any required fencing, enclosure, vault or cabinet shall conform with applicable laws, codes, and ordinances of governmental authorities having jurisdiction and PG&E physical security requirements. Applicant shall not have access to the Standalone Power System Equipment area.

3. Design and Installation of Standalone Power System.

Electric Service by the Standalone Power System shall be provided under the following terms and conditions:

- A. PG&E will be responsible for the planning, design, and engineering of the Standalone Power System. The Applicant Design Option provisions of Rules 15 and 16 are not available for Standalone Power System equipment, with the exception of the Service Facilities that extend from the Standalone Power System equipment area to the Service Delivery Point. The Standalone Power System shall not be deemed to be the nearest available permanent Distribution Line for purposes of New Distribution Line extensions under Electric Rule 15 or connections for new service extensions under Electric Rule 16.
- B. The installed capacity of the Standalone Power System at the Premises (and therefore the peak power and maximum energy usage that the Applicant will be able to draw from the Standalone Power System) will be determined by PG&E based on the Applicant's load and energy usage information provided in accordance with Rule 3 but not exceeding the capacity as designed.
- C. If, after the date PG&E is first ready to provide service, the Applicant has a need for increased load at the Premises from the installed capacity (and therefore the peak power and maximum energy usage that may be consumed from the Standalone Power System):

STANDALONE POWER SYSTEM SUPPLEMENTAL PROVISIONS

- 1) the Applicant must notify PG&E of the changes in load usage or characteristics of the load, per Electric Rule 3;
 - 2) PG&E will work with the Applicant to optimize the Applicant's demand profile; if PG&E and the Applicant are unable to agree how to optimize the customer's demand profile such that the fuel powered generator forming part of the Standalone Power System will not run out of fuel between refueling visits, PG&E is not obliged to supply additional fuel to the generator forming part of the Standalone Power System outside of scheduled refueling visits. This may result in the Applicant experiencing outages.
- D. If, after the date PG&E is first ready to provide service, the Applicant requests an increase in the peak power and maximum energy usage that the Applicant can draw from the Standalone Power System, PG&E will consider this request and may request reasonable information from the Applicant to enable PG&E to make a determination, in its sole discretion, as to whether it can increase the installed capacity of the Standalone Power System. When PG&E determines an increase in the installed capacity of the Standalone Power System would require replacement or reinforcement, such replacement or reinforcement shall be treated in the same manner as for Distribution Lines.
- 4. On-Site Generation.**
- A. Service by the Standalone Power System may decrease the amount of electricity that can be exported from the Premises because that export will be to the energy storage system component of the Standalone Power System, which will have limited capacity and which is designed to store electricity generated by the Standalone Power System. As is the case under current PG&E rules, Applicant must not install or permit the installation of any permanent on-site electricity generation or storage system on the Premises (or any other location that may service the Premises) without PG&E's prior written consent. The installation of permanent generation must follow the requirements specified in PG&E's Rule 21.
 - B. Applicant must not install or permit the installation of any temporary generation for emergency power or for trades personnel to undertake work at the Premises without PG&E's prior written consent. The installation of temporary generators including for emergency, standby, backup, or momentary paralleling purposes must follow the guidelines specified in PG&E's Distribution Interconnection Handbook.
- 5.** Except as otherwise expressly provided herein, these Supplemental Provisions shall be subject to all of PG&E's applicable tariff schedules on file and authorized by the Commission. These Supplemental Provisions shall at all times be subject to such changes or modifications as the Commission may direct from time to time in the exercise of its jurisdiction.
- 6. Termination of Agreement.**
- A. PG&E reserves the right to terminate this Agreement upon no shorter than thirty (30) days' written notice and to thereafter provide electric service to Applicant through an alternative method of service in accordance with Rules 15/16, including by a conventional Distribution Line Extension that may be constructed in the future.
 - B. Applicant may terminate this Agreement by electing to no longer receive electrical service from PG&E via the Standalone Power System. To elect such a termination, Applicant shall provide PG&E with written notice no less than thirty (30) days prior to the date of such termination. Applicant acknowledges and agrees that where Remote Grid Service is the sole standard service offering for Applicant, by terminating this Agreement and electing to no longer receive electrical service from PG&E via the Standalone Power System, Applicant elects to no longer receive standard electrical service from PG&E. If Applicant terminates this Agreement and PG&E offers standard service to the Applicant other than via the Standalone Power System, Applicant may elect to receive such service by submitting a new application for service with



STANDALONE POWER SYSTEM SUPPLEMENTAL PROVISIONS

PG&E. Any requisite line extensions will be pursuant to the requirements of PG&E's line extension rules in effect at the time of such application including Rules 15 and 16.

- 7. **Bundled Service Rates.** Applicant may select from any Electric Rate Schedule for which the Applicant qualifies pursuant to the Electric Rate Schedule and these Supplemental Provisions, for purposes of billing for the electric services received. Applicant agrees to pay for all rates in the Electric Rate Schedule, which may include unbundled rate components for services that may not be provided to Applicant during the term of this Agreement.

Pacific Gas and Electric Company

Applicant

This contract has been reviewed and approved by:

Agreed and accepted by:

Authorized Name: _____

Applicant's Legal Name: _____

Title: _____

Title: _____

Signature: _____

Signature: _____

Date: _____

Date: _____