

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans
Rulemaking 18-10-007
Data Response

PG&E Data Request No.:	CalAdvocates_055-Q06		
PG&E File Name:	WildfireMitigationPlans_DR_CalAdvocates_055-Q06		
Request Date:	April 26, 2021	Requester DR No.:	2021WMP-021
Date Sent:	April 29, 2021	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Alan Wehrman

QUESTION 06

For transmission tower climbing inspections PG&E has performed in HFTDs in 2021 to date, please answer the following:

- a) How many transmission tower climbing inspections have been performed in HFTDs to date? Please specify the end date for your tally.
- b) What was the typical size of crews that performed these inspections (how many people per crew)? If there is significant variation, please provide the range and median crew size.
- c) How many crews performed these inspections?
- d) What was the mean time in person-hours spent on these climbing inspections?
- e) What was the median time in person-hours spent on these climbing inspections?
- f) Please provide a table with a similar breakdown as the one requested in Question 5 for the transmission tower climbing inspections performed in HFTDs in 2021 to date.

ANSWER 06

- a) As of 4/28/2021, 948 climbing inspections have been completed in HFTD areas
- b) 5 Man Tower Crew
- c) 3 to 4
- d) 12 hours a day, 5 days a week
- e) See response to 6(d)

f)

	HFTD Transmission
Total	179
CNCL/DLFL	78
Duplicates	9
LC	85
A	0
B	3
E	78
F	4
Pending S5	16