

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans**  
**Rulemaking 18-10-007**  
**Data Response**

PG&E Data Request No.:	WSD_010-Q04		
PG&E File Name:	WildfireMitigationPlans_DR_WSD_010-Q04		
Request Date:	March 15, 2021	Requester DR No.:	WSD to PGE – Data Request – 20210315
Date Sent:	March 18, 2021	Requesting Party:	Wildfire Safety Division
PG&E Witness:		Requester:	Ryan Arba

**QUESTION 04**

Regarding the variables in Table PG&E-4.3-3, p. 102 PG&E 2021 WMP:

- a. How many ACSR, Cu, and Al ignitions were used as inputs to train the Equipment Probability of Ignition Model?

**ANSWER 04**

- a. There were 103 ACSR, 37 Copper, and 19 Aluminum conductor related ignitions.