

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2022
Data Response**

PG&E Data Request No.:	CalAdvocates_028-Q01		
PG&E File Name:	WMP-Discovery2022_DR_CalAdvocates_028-Q01		
Request Date:	July 27, 2022	Requester DR No.:	CalAdvocates-PGE-2022WMP-28
Date Sent:	August 1, 2022	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Holly Wehrman

The following questions relate to PG&E's July 26, 2022 response to the Revision Notice For Pacific Gas And Electric Company's 2022 Wildfire Mitigation Plan Update issued by Energy Safety on May 26, 2022 (hereinafter, PG&E's response to the revision notice).

QUESTION 01

- a) How many total ignitions has PG&E experienced related to underground distribution lines from January 1, 2015 through June 30, 2022?
- b) How many total ignitions has PG&E experienced related to overhead distribution lines from January 1, 2015 through June 30, 2022?

ANSWER 01

- a) PG&E has observed 46 CPUC-reportable ignitions attributable to underground and subsurface distribution assets from January 1, 2015 to June 30, 2022.
- b) PG&E has observed 3,317 CPUC-reportable ignitions attributable to overhead distribution assets from January 1, 2015 to June 30, 2022.