

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans Discovery 2023-2025**  
**Data Response**

PG&E Data Request No.:	MGRA_009-Q013		
PG&E File Name:	WMP-Discovery2023-2025_DR_MGRA_009-Q013		
Request Date:	April 8, 2024	Requester DR No.:	MGRA Data Request No. 2
Date Sent:	April 11, 2024	Requesting Party:	Mussey Grade Road Alliance
PG&E Witness:		Requester:	Joseph Mitchell

**Early Fault Detection/Distribution Fault Anticipation**

**QUESTION 013**

Are EFD circuits being deployed on circuits that are being scoped for undergrounding?

**ANSWER 013**

PG&E has avoided selecting circuits/circuit segments with known undergrounding schedules for Early Fault Detection (EFD) deployment.