

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2022
Data Response**

PG&E Data Request No.:	CalAdvocates_014-Q04		
PG&E File Name:	WMP-Discovery2022_DR_CalAdvocates_014-Q04		
Request Date:	March 10, 2022	Requester DR No.:	CalAdvocates-PGE-2022WMP-14
Date Sent:	March 15, 2022	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Dillon Copa

The following questions relate to your 2022 WMP Update submission.

QUESTION 04

On Pg. 445 of PG&E's 2022 WMP, PGE&E states, "In 2021, PG&E replaced 16,359 poles and reinforced 3,012 poles."

- a) Please provide a .gdb spatial file showing where PG&E replaced poles.
- b) Please provide a .gdb spatial file showing where PG&E reinforced poles.

ANSWER 04

- a. Reference attachment WMP-Discovery2022_DR_CalAdvocates_014-Q04Atch01 for locations where PG&E replaced poles in 2021. There are approximately 290 locations missing from this file, which are tree attachments that were not mapped in EDGIS prior to replacement. For all these locations, we installed a new utility pole and transferred our facilities from the tree to the new utility pole. This work is part of our pole replacement program.
- b. Reference attachment WMP-Discovery2022_DR_CalAdvocates_014-Q04Atch01 for locations where PG&E reinforced poles in 2021. There are approximately 40 locations missing from this file, where the pole has been replaced due to another reason (e.g. major emergency, system hardening, new business, work at the request of others, etc.).