

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response

PG&E Data Request No.:	CalAdvocates_003-Q003		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_003-Q003		
Request Date:	February 7, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-03
Date Sent:		Requesting Party:	Public Advocates Office
DRU Index #:	DRU11413	Requester:	Holly Wehrman

QUESTION 003

Provide an Excel table of all distribution circuits existing as of January 1, 2022 (as rows) that were removed or decommissioned in 2022, either partially or entirely. This includes permanent removal, removal of overhead lines that were moved underground, or overhead lines that were decommissioned but not physically removed. Include the following information in separate columns.

- a. Circuit name
- b. Circuit ID number
- c. Circuit miles removed or decommissioned in Non-HFTD Areas
- d. Circuit miles removed or decommissioned in Other HFTD
- e. Circuit miles removed or decommissioned in HFTD Tier 2
- f. Circuit miles removed or decommissioned in HFTD Tier 3
- g. Reason(s) for removal or decommissioning

ANSWER 003

Attached is "WMP-Discovery2023_DR_CalAdvocates_003-Q003Atch01.xlsx", which provides information regarding removals of primary distribution lines in HFTD in 2022, which is the subset of the requested information available at this time. PG&E does not track line removals when relocating overhead to underground, removing secondary services, or removing lines in non-HFTD. Further, our GIS cannot be used to obtain this information retroactively because when mapping removals, the electric assets are removed from GIS.

Below we provide additional information to clarify the data provided in the attachment in response to the request.

- a. Circuit name: See column C.
- b. Circuit ID number: See column D.
- c. Circuit miles removed or decommissioned in Non-HFTD Areas: N/A. As noted above, PG&E does not track line removals when relocating overhead to underground, removing secondary services, or removing lines in non-HFTD .

- d. Circuit miles removed or decommissioned in Other HFTD: N/A. PG&E does not track line removals when relocating overhead to underground, removing secondary services, or removing lines in non-HFTD.
- e. Circuit miles removed or decommissioned in HFTD Tier 2: Column E indicates if the project in the unique circuit segment is in either a Tier 2 and/or Tier 3 HFTD, and column G includes the associated circuit miles.
- f. Circuit miles removed or decommissioned in HFTD Tier 3: Column E indicates if the project in the unique circuit segment is in either a Tier 2 and/or Tier 3 HFTD, and column G includes the associated circuit miles.
- g. Reason(s) for removal or decommissioning: See Column F, which notes the name of one of three programs:
 - (1) Fire Rebuild – Removal based on rebuilding in the aftermath of wildfires;
 - (2) Idle Facilities – Unused facilities with no foreseeable future use; or
 - (3) Base SH (System Hardening) – Removal based on the risk-informed criteria used in PG&E's System Hardening Program.