

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response

PG&E Data Request No.:	CalAdvocates_006-Q014		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_006-Q014		
Request Date:	February 10, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-06
Date Sent:	March 29, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission.

If a full response to a given question will be included in your WMP submission, your response to that question of this data request may consist of a citation to the specific page(s) or table(s) of the WMP where the information may be found, a written response to the question, or both.

Topic: Ignitions

QUESTION 014

Identify any ignitions in 2022 associated with assets where you had an existing corrective notification at the time of the ignition. Please provide a spreadsheet listing each such ignition (as rows) with the following information in separate columns:

- a) Unique ignition ID
- b) Date of ignition
- c) Cause of ignition
- d) Type of asset associated with the ignition
- e) Acres burned
- f) Number of structures burned, if any
- g) Number of injuries associated with ignition, if any
- h) Asset ID of asset associated with ignition
- i) Circuit ID number of circuit associated with ignition
- j) Notification number(s) for the existing maintenance tag on the asset in question.

ANSWER 014

Please see the table below identifying 2022 CPUC reportable ignitions where the asset involved in the ignition was associated with an existing open corrective maintenance notification at the time of the event.

Ignition ID	Date of Ignition	Suspected Cause	Equipment Type Associated With Ignition	Fire Size	Structures Destroyed	Injuries	Asset ID	Circuit ID	Existing Maintenance Notifications
20220374	4/6/2022	Equipment Failure	Conductor - Primary	0.26-9.99 Acres	0	0	101894229	MESA 1103	121931783
20220613	5/17/2022	Equipment Failure	Splice/ Clamp/ Connector	1 meter - <3 meters	0	0	102242348	SAN RAFAEL 1104	119372723
20220740	6/2/2022	Equipment Failure	Service Drop	1 meter - <3 meters	0	0	103319095	MC CALL 1101	123226356
20221200	7/19/2022	Equipment Failure	Conductor - Primary	<1 Acre	0	0	101710681	WATSONVILLE 2101	123651178
20221314	8/3/2022	Equipment Failure	Splice/Clamp /Connector	1 Acre	0	0	101850483	FOOTHILL 2101	123700083
20221278	7/28/2022	Equipment Failure	Pole	<0.25 Acre	0	0	101137014	MADERA 1118	118429275
20222013	11/16/2022	Equipment Failure	Crossarm	<0.25 Acre	0	0	101424195	FAIRVIEW 2207	123866774