

Just for PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response

PG&E Data Request No.:	CalAdvocates_006-Q014		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_006-Q014		
Request Date:	February 10, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-06
Date Sent:	March 29, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission.

If a full response to a given question will be included in your WMP submission, your response to that question of this data request may consist of a citation to the specific page(s) or table(s) of the WMP where the information may be found, a written response to the question, or both.

Topic: Ignitions

QUESTION 014

- a) Has PG&E's Asset Failure Analysis Team causally connected any ignitions that occurred in 2022 to assets with existing asset or vegetation corrective notifications at the time of ignition?
- b) If the answer to part (a) is yes, please provide the following information on each such ignition:
 - i. Unique ignition ID (matching the previous question).
 - ii. Date of ignition.
 - iii. Cause(s) identified by the Asset Failure Analysis Team.
 - iv. The type of corrective notification that was linked to the ignition (i.e., the priority level and whether it related to asset management or vegetation management).
 - v. Copies of associated reports or investigations performed by the Asset Failure Analysis Team.

ANSWER 014

- a) Yes, please see below.
- b) Two ignitions have been identified that meet these criteria:

Ignition ID	Date of Ignition	Cause	Type of Corrective Notification	Copies of Associated Reports
20221278	7/28/2022	The cause of this ignition is still being finalized.	EC Notification 118429275 – Pole Replacement	The report in question is still being finalized and can be provided upon completion.
20222013	11/16/2022	Broken crossarm	EC Notification 123866774 – Crossarm replacement (later updated to pole replacement)	The report in question is still being finalized and can be provided upon completion.