

**PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023
Data Response**

PG&E Data Request No.:	CalAdvocates_019-Q004		
PG&E File Name:	WMP-Discovery2023_DR_CalAdvocates_019-Q004		
Request Date:	April 25, 2023	Requester DR No.:	CalAdvocates-PGE-2023WMP-19
Date Sent:	April 28, 2023	Requesting Party:	Public Advocates Office
DRU Index #:		Requester:	Holly Wehrman

The following questions relate to your 2023-2025 WMP submission and your responses to data request CalAdvocates-PGE-2023WMP-15.

QUESTION 004

- a) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for vegetation management for an overhead distribution line installed in the HFTD?
- b) In 2023, what is the average per-circuit-mile cost that PG&E expects to incur for vegetation management for an underground distribution line installed in the HFTD?

ANSWER 004

- a) Based on 2019-2022 data, our cost for vegetation management maintenance systemwide was approximately \$8,500 per mile. We expect to incur similar costs in 2023. Costs for vegetation management are not forecast separately between HFTD and Non-HFTD.
- b) We do not separately forecast an average per-circuit mile cost incurred for vegetation management for an underground distribution line installed in HFTD.