

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans Discovery 2023-2025**  
**Data Response**

PG&E Data Request No.:	MGRA_009-Q005		
PG&E File Name:	WMP-Discovery2023-2025_DR_MGRA_009-Q005		
Request Date:	April 8, 2024	Requester DR No.:	MGRA Data Request No. 2
Date Sent:	April 11, 2024	Requesting Party:	Mussey Grade Road Alliance
PG&E Witness:		Requester:	Joseph Mitchell

**PS-07: Reduce PSPS Impacts to Customers (Section 9.1.5)**

**QUESTION 005**

For the 22k to 13k reduction in customers exposed to PSPS events, how much of the reduction is due to 1) undergrounding 2) Motorized Switch Operations (MSOs), and 3) other factors.

**ANSWER 005**

All of the reduction from 22k to 13k is attributed to undergrounding. As mentioned in section B.2.1.1.3 of the 2025 WMP, the number of undergrounding miles for 2025 was adjusted from 550 miles to 330 miles, therefore the reduction in customer events mitigated corresponds proportionally to the decrease in undergrounding miles completed. No customer events mitigated from Motorized Switch Operations (MSO) replacements are expected in 2025 as the program is expected to be completed in 2024.