

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans Discovery 2023-2025**  
**Data Response**

PG&E Data Request No.:	CalAdvocates_050-Q002		
PG&E File Name:	WMP-Discovery2023-2025_DR_CalAdvocates_050-Q002		
Request Date:	June 24, 2024	Requester DR No.:	CalAdvocates-PGE-2025WMP-14
Date Sent:	July 9, 2024	Requesting Party:	Public Advocates Office
PG&E Witness:		Requester:	Amanda Asadi

The following question relates to PG&E's response to data request CalAdvocates-PGE-2023WMP-34.

**QUESTION 002**

In response to Data request CalAdvocates-PGE-2023WMP-34, Question 1, PG&E states, "no additional action required" for 36 circuits in 2022. Please explain why no additional action was required.

**ANSWER 002**

PG&E used the term "no additional action required" in the referenced data request to account for when a review was complete and the previously identified action items were either appropriate or additional actions items were not required due to one of the following reasons upon reviewing the outages and causes:

- Outage Frequency (i.e., outages occurred across a long period of time on the circuit)
- Cause Type (for example, a 3<sup>rd</sup> Party - Car Pole outage triggering a MORE review)

PG&E would then continue to monitor the circuit for additional outages that may result in new action items as needed.