

PACIFIC GAS AND ELECTRIC COMPANY
Wildfire Mitigation Plans Discovery 2023-2025
Data Response

PG&E Data Request No.:	SPD_014-Q005		
PG&E File Name:	WMP-Discovery2023-2025_DR_SPD_014-Q005		
Request Date:	May 14, 2024	Requester DR No.:	SPD_WSPS_PG&E_004
Date Sent:	May 28, 2024	Requesting Party:	Safety Policy Division
PG&E Witness:		Requester:	Henry Sweat

QUESTION 005

Provide number of A, B, X, E, F for Aerial, Ground and Pole Test and Treat finds during inspections in 2023, and 2024 broken down by HFTD and non-HFTD. Include number of inspections and find rate for each tag type. Submit the same information in the same format as *Table RN-PG&E-23-04-7* (attached in email) for 2023 and 2024 from PG&E's 2023-2025 *Wildfire Mitigation Plan Supplemental Response to Revision Notice*, except provide the actual tag finds, rather than "Forecast Tag Finds." Indicate if helicopters or planes were used for any of the aerial inspections.

ANSWER 005

2023-2024 Actual Finds by Inspection Type

			Annual Inspections 2023			Annual Inspections 2024 (YTD)		
Inspection Type	Tier	Priority	Find Rate	Actual Inspections by Tier	Actual Tag Find	Find Rate	Actual Inspections by Tier	Actual Tag Find
Aerial	Non-HFTD /HFRA	A	#N/A*	700	#N/A*	0.32%	1,581	5
		X	#N/A*		#N/A*	0.89%		14
		B	#N/A*		#N/A*	1.14%		18
		E	#N/A*		#N/A*	15.31%		242
		F	#N/A*		#N/A*	0.38%		6
	Tier 2	A	#N/A*	30,000	#N/A*	0.25%	42,538	107
		X	#N/A*		#N/A*	0.50%		214
		B	2.58%		774	3.20%		1,361
		E	1.57%		471	13.74%		5,844
		F	0.49%		147	0.40%		170
	Tier 3	A	#N/A*	7,300	#N/A*	0.23%	25,762	58
		X	#N/A*		#N/A*	0.47%		120
		B	2.42%		177	3.53%		910
		E	0.82%		60	12.67%		3,263
		F	0.22%		16	0.42%		109
Ground	Non-HFTD /HFRA	A	0.73%	4,908	36	4.76%	84	4
		X	0.00%		0	0.00%		0
		B	2.38%		117	0.00%		0
		E	27.87%		1,368	2.38%		2

			Annual Inspections 2023			Annual Inspections 2024 (YTD)		
Inspection Type	Tier	Priority	Find Rate	Actual Inspections by Tier	Actual Tag Find	Find Rate	Actual Inspections by Tier	Actual Tag Find
		F	7.58%		372	1.19%		1
	Tier 2	A	0.46%	221,021	1,006	1.30%	1,926	25
		X	0.00%		0	0.52%		10
		B	3.32%		7,327	3.01%		58
		E	27.00%		59,670	9.29%		179
		F	5.27%		11,654	2.80%		54
	Tier 3	A	1.06%	9,803	104	1.54%	455	7
		X	0.00%		0	0.22%		1
		B	2.54%		249	3.08%		14
		E	15.21%		1,491	13.19%		60
		F	4.09%		401	4.62%		21
	Zone 1	A	0.67%	1,486	10	0.00%	47	0
		X	0.00%		0	0.00%		0
		B	1.88%		28	2.13%		1
		E	21.40%		318	6.38%		3
		F	3.97%		59	6.38%		3
PTT	Non-HFTD /HFRA	A	0.00%	504	0	0.00%	83	0
		X	0.00%		0	1.20%		1
		B	0.99%		5	0.00%		0
		E	2.98%		15	3.61%		3
		F	0.00%		0	0.00%		0
	Tier 2	A	0.00%	11,684	0	0.10%	2,041	2
		X	0.00%		0	0.00%		0
		B	0.39%		45	0.83%		17
		E	4.73%		553	5.19%		106
		F	0.00%		0	0.10%		2
	Tier 3	A	0.00%	7,321	0	0.00%	956	0
		X	0.00%		0	0.00%		0
		B	0.18%		13	0.31%		3
		E	4.66%		341	5.54%		53
		F	0.00%		0	0.10%		1
	Zone 1	E	5.26%	76	4	0.00%	8	0

*-PG&E is using the same aerial data for 2023 that was previously provided in Table RN-PG&E-23-04-7 since it was based off 2023 actuals, per footnote (a).

Note: No helicopters or planes were used for any of the aerial inspections. Only drones were used.