

**PACIFIC GAS AND ELECTRIC COMPANY**  
**Wildfire Mitigation Plans Discovery 2023-2025**  
**Data Response**

PG&E Data Request No.:	SPD_014-Q007		
PG&E File Name:	WMP-Discovery2023-2025_DR_SPD_014-Q007		
Request Date:	May 14, 2024	Requester DR No.:	SPD_WSPS_PG&E_004
Date Sent:	May 28, 2024	Requesting Party:	Safety Policy Division
PG&E Witness:		Requester:	Henry Sweat

**QUESTION 007**

Provide the count of tags for each tag type in 2024 where an existing tag was re-prioritized to a more urgent priority and the priority to which it was re-assigned due to an inspection.

**ANSWER 007**

PG&E interprets this as a request for tags that were re-prioritized to a more urgent priority during an inspection and not during the oversight process. This would occur when an asset with an existing tag was scheduled for an inspection due to General Order 165 requirements.

Please see the table below for the requested information.

Original Priority	Tag Count	Escalated Priority
B	0	N/A
E	216	B
F	62	B

Please note, A tags are the highest priority. Tags identified as X priority can get upgraded to an A priority, however, this occurs procedurally, and not during an inspection.