

POSTING REQUIREMENTS FOR FERC STANDARDS OF CONDUCT PACIFIC GAS AND ELECTRIC COMPANY

FERC Standards of Conduct, Section 358.7(a): If a transmission provider discloses non-public transmission function information, other than information identified in paragraph (a)(2) of this section, in a manner contrary to the requirements of § 358.6, the transmission provider must immediately post the information that was disclosed on its Internet website.

In preparation for a potential Public Safety Power Shutoff (PSPS) event that is forecasted to commence the early morning of 10/9/2019, on 10/7/2019 Pacific Gas and Electric Company (PG&E) notified potentially affected customers that the transmission lines identified below may be de-energized during the PSPS event.

Transmission Lines that may be de-energized:

FULTON-LAKEVILLE-IGNACIO	230
IGNACIO-SOBRANTE	230
LAKEVILLE-SOBRANTE #2	230
METCALF-MONTA VISTA #3	230
MIDDLE FORK-GOLD HILL	230
MONTA VISTA-COYOTE SW STA	230
PIT #6 JCT-ROUND MTN	230
TIGER CREEK-ELECTRA	230
TIGER CREEK-VALLEY SPRINGS	230
APPLE HILL #1 TAP	115
APPLE HILL #2 TAP	115
BRIDGEVILLE-COTTONWOOD	115
CARIBOU-PALERMO	115
CASCADE-COTTONWOOD	115
CORTINA-MENDOCINO #1	115
CRAG VIEW-CASCADE	115
DONNELLS-MI-WUK	115
DRUM PH #2 TAP	115
DRUM-HIGGINS	115
DRUM-RIO OSO #1	115
DRUM-RIO OSO #2	115
DRUM-SUMMIT #1	115
DRUM-SUMMIT #2	115
DUTCH FLAT #2 TAP	115
EAGLE ROCK-CORTINA	115
EAGLE ROCK-REDBUD	115

EL DORADO-MISSOURI FLAT #1	115
EL DORADO-MISSOURI FLAT #2	115
MENDOCINO-REDBUD	115
MI-WUK-CURTIS	115
PARADISE-BUTTE	115
PARADISE-TABLE MTN	115
SLY CREEK TAP	115
SOBRANTE-GRIZZLY-CLAREMONT #1	115
SOBRANTE-GRIZZLY-CLAREMONT #2	115
TRINITY-COTTONWOOD	115
WOODLEAF-PALERMO	115
BURNS-LONE STAR #1	60
BURNS-LONE STAR #2	60
CAPE HORN TAP	60
CASCADE-BENTON-DESCHUTES	60
CENTERVILLE-TABLE MTN	60
CENTERVILLE-TABLE MTN-OROVILLE	60
CLOVER CREEK TAP	60
COLEMAN-COTTONWOOD	60
COLEMAN-RED BLUFF	60
COLGATE-ALLEGHANY	60
COLGATE-CHALLENGE	60
COLGATE-GRASS VALLEY	60
COLGATE-PALERMO	60
COLGATE-SMARTVILLE #2	60
COTTONWOOD #1	60
COTTONWOOD #2	60
COTTONWOOD-BENTON #1	60
COTTONWOOD-BENTON #2	60
COTTONWOOD-RED BLUFF	60
DEER CREEK-DRUM	60
DESABLA-CENTERVILLE	60
DRUM-GRASS VALLEY-WEIMAR	60
DRUM-SPAULDING	60
FORKS OF THE BUTTE TAP	60
FRENCH MEADOWS-MIDDLE FORK	60
FULTON-CALISTOGA	60
FULTON-HOPLAND	60
GOLD HILL #1	60
HALSEY-PLACER	60
HILLSDALE JCT-HALF MOON BAY	60

KESWICK-CASCADE	60
KILARC-CEDAR CREEK	60
KILARC-DESCHUTES	60
KILARC-VOLTA TIE	60
KONOCTI-EAGLE ROCK	60
LAKEVILLE #1	60
MENDOCINO-HARTLEY	60
MIDDLE FORK #1	60
MONTA VISTA-BURNS	60
MTN GATE JCT-CASCADE	60
ORO FINO TAP	60
OXBOW TAP	60
PALERMO-OROVILLE #1	60
PINE GROVE TAP	60
POTTER VALLEY-WILLITS	60
ROLLINS TAP	60
SMARTVILLE-MARYSVILLE	60
SMARTVILLE-NICOLAUS #2	60
SNEATH LANE-HALF MOON BAY	60
SPAULDING-SUMMIT	60
TULUCAY-NAPA #1	60
VOLTA-DESCHUTES	60
VOLTA-SOUTH	60
WEIMAR #1	60
WEIMAR-HALSEY	60
WEST POINT-VALLEY SPRINGS	60
Fulton-Ignacio #1-230kV line	230
Pit #6 230kV tap	230
Pit #7 230kV tap	230
Beardsley 115kV tap	115
Brunswick #1-115kV tap	115
Brunswick #2-115kV tap	115
Kanaka 115kV tap	115
Lower Lake-Homestake 115kV line	115
Salt Springs-Tiger Creek 115kV line	115
Sand Bar 115kV tap	115
Spring Gap 115kV tap	115
Coleman-South 60kV line	60
Delta-Mountain Gate JCT 60kV line	60
Fitch Mountain #1-60kV tap	60
Lone Star 60kV tap	60

Mountain Quarries 60kV tap	60
Narrows #2-60kV tap	60
Nicolaus-Catlett JCT 60kV line	60

Posted: 10/7/2019