

POSTING REQUIREMENTS FOR FERC STANDARDS OF CONDUCT PACIFIC GAS AND ELECTRIC COMPANY

FERC Standards of Conduct, Section 358.7(a): If a transmission provider discloses non-public transmission function information, other than information identified in paragraph (a)(2) of this section, in a manner contrary to the requirements of § 358.6, the transmission provider must immediately post the information that was disclosed on its Internet website.

In preparation for a potential Public Safety Power Shutoff (PSPS) event that is forecasted to commence the evening of 10/23/2019, on 10/21/2019 Pacific Gas and Electric Company (PG&E) notified potentially affected customers that the transmission lines identified below may be de-energized during the PSPS event.

Transmission Lines that may be de-energized:

FULTON-LAKEVILLE-IGNACIO	230
TIGER CREEK-ELECTRA	230
TIGER CREEK-VALLEY SPRINGS	230
APPLE HILL #1 TAP	115
APPLE HILL #2 TAP	115
CARIBOU-PALERMO	115
DRUM-HIGGINS	115
DRUM-RIO OSO #1	115
DRUM-RIO OSO #2	115
DUTCH FLAT #2 TAP	115
EL DORADO-MISSOURI FLAT #1	115
EL DORADO-MISSOURI FLAT #2	115
WOODLEAF-PALERMO	115
CAPE HORN TAP	60
CENTERVILLE-TABLE MTN	60
CENTERVILLE-TABLE MTN-OROVILLE	60
COLGATE-ALLEGHANY	60
COLGATE-CHALLENGE	60
COLGATE-GRASS VALLEY	60
DEER CREEK-DRUM	60
DESABLA-CENTERVILLE	60
DRUM-GRASS VALLEY-WEIMAR	60
FORKS OF THE BUTTE TAP	60
FULTON-CALISTOGA	60
FULTON-HOPLAND	60
MIDDLE FORK #1	60

ORO FINO TAP	60
OXBOW TAP	60
PALERMO-OROVILLE #1	60
PINE GROVE TAP	60
ROLLINS TAP	60
WEIMAR #1	60
WEIMAR-HALSEY	60
WEST POINT-VALLEY SPRINGS	60
BRUNSWICK #1-115KV TAP	115
BRUNSWICK #2-115KV TAP	115
KANAKA 115KV TAP	115
SALT SPRINGS-TIGER CREEK 115KV LINE	115
FITCH MOUNTAIN #1-60KV TAP	60

Posted: 10/21/2019